

Certificate

The manufacturer is awarded the following type test approval mark in virtue of a component test report:

Category type test approval mark:

valve

Technical inspection and surveillance organisation and test report:

TÜV NORD dated 2016-07-19 and the 3rd supplement of 2026-07-27

Manufacturer/Distributor:

ELAFLEX Hiby GmbH & Co. KG
Schnackenburgallee 121
22525 Hamburg
GERMANY

Type test approval mark:

TÜV . A . 367 - 26

Design:

Cable-operated breakaway coupling (path-controlled) with self-closing, spring-loaded non-return valves, engageable under operating pressure, nominal diameter DN 19

Type:

ARK 19, ARK 19 SS

The award is made pursuant to:

- TÜV-Verband-Merkblatt Armatur 100, edition 2022-12-14, in conjunction with TÜV-Verband Technical Leaflet General 002, edition 2026-06-01
- Directive 2014/68/EU of 15 May 2014 (Pressure Equipment Directive)
- AD 2000 Code
- EN 14678-1:2013-06
- TRGS 751, edition 2024-02

Valid until:

2031-07-31

The award may be revoked. The previous certificate is replaced herewith.

Note: The manufacturer or importer must task the authorised inspector with conducting a yearly random check of components from the production line to establish their conformity with the approved type.

TÜV-Verband e. V.
Friedrichstraße 136
10117 Berlin

phone: +49 30 760095-400
e-mail: bauteile@tuev-verband.de

Industry and plant engineering division

www.tuev-verband.de/en